



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

Trade Name:	AKRONEX 1230
Chemical Identification:	dodecafluoro-2-methylpentan-3-one, $\text{CF}_3\text{CF}_2\text{C}(\text{O})\text{CF}(\text{CF}_3)_2$
Designation:	FK-5-1-12
Minimum Extinguishing Concentrations:	Class A – 5.26%
	Class B – 5.67%

Approval Guide Listing Category: Fixed Extinguishing Systems, Clean Extinguishing Agents

AKRONEX INTERNATIONAL FIRE ENGINEERING INC.
Istasyon Mah, 1495 Sok. No:13
41400 Gebze, Kocaeli
Turkey

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

<i>Approval Standards</i>	
<i>Class Number</i>	<i>Date</i>
5600	September 2020

FM Approvals Listing Class: 5613

Project Identification: PR460694
Subsequent Revisions: None

Approval Granted: 9 September 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

A handwritten signature in dark ink, appearing to read 'J.E. Marquedant', written over a horizontal line.

James E. Marquedant
VP, Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

9 September 2021

Date



Member of the FM Global Group